

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 28)**

Water Level of the accumulated water (at 7:00 on June 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,436 mm (10 mm increase since 7:00 on June 27)	O.P.+ 2,477 mm (5 mm decrease since 7:00 on June 27)	—
	Water level of Turbine Building	O.P.+ 2,699 mm (13 mm increase since 7:00 on June 27)	O.P.+ 2,769 mm (83 mm increase since 7:00 on June 27)	O.P.+ 2,901 mm (33 mm increase since 7:00 on June 27)	O.P.+ 2,845 mm (6 mm increase since 7:00 on June 27)
	Water level of Reactor Building	O.P.+ 4,019 mm (68 mm increase since 7:00 on June 27)	O.P.+ 2,891 mm (44 mm increase since 7:00 on June 27)	O.P.+ 2,953 mm (25 mm increase since 7:00 on June 27)	O.P.+ 2,848 mm (2 mm increase since 7:00 on June 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,544 mm (Increase from initial level:5,761 mm, 5 mm increase since 7:00 on June 27) O.P.+ 1,447 mm (Increase from initial level:2,173 mm, 542 mm decrease since 7:00 on June 27) O.P.+ 4,393 mm (Water level from floor:597 mm, 3 mm increase since 7:00 on June 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:25 on June 21 to 10:10 on June 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:39 on June 25 to 9:50 on June 27)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:30 on June 23   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:48 on June 25   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.