

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 29)**

Water Level of the accumulated water (at 7:00 on June 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,434 mm (2 mm decrease since 7:00 on June 28)	O.P.+ 2,474 mm (3 mm decrease since 7:00 on June 28)	—
	Water level of Turbine Building	O.P.+ 2,503 mm (196 mm decrease since 7:00 on June 28)	O.P.+ 2,758 mm (11 mm decrease since 7:00 on June 28)	O.P.+ 2,863 mm (38 mm decrease since 7:00 on June 28)	O.P.+ 2,850 mm (5 mm increase since 7:00 on June 28)
	Water level of Reactor Building	O.P.+ 4,059 mm (40 mm increase since 7:00 on June 28)	O.P.+ 2,901 mm (10 mm increase since 7:00 on June 28)	O.P.+ 2,921 mm (32 mm decrease since 7:00 on June 28)	O.P.+ 2,851 mm (3 mm increase since 7:00 on June 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,547 mm (Increase from initial level:5,764 mm, 3 mm increase since 7:00 on June 28) O.P.+ 1,608 mm (Increase from initial level:2,334 mm, 161 mm increase since 7:00 on June 28) O.P.+ 4,395 mm (Water level from floor:599 mm, 2 mm increase since 7:00 on June 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 11:43 on June 28 to 17:45 on June 28)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:17 on June 28)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:22 on June 28)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:30 on June 23 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:48 on June 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.