

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 1)**

Water Level of the accumulated water (at 7:00 on July 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 797 mm (No change since 7:00 on June 30)	O.P.+ 2,137 mm (334 mm decrease since 7:00 on June 30)	—
	Water level of Turbine Building	O.P.+ 2,533 mm (15 mm increase since 7:00 on June 30)	O.P.+ 2,814 mm (74 mm increase since 7:00 on June 30)	O.P.+ 2,885 mm (58 mm increase since 7:00 on June 30)	O.P.+ 2,841 mm (2 mm decrease since 7:00 on June 30)
	Water level of Reactor Building	O.P.+ 4,079 mm (8 mm increase since 7:00 on June 30)	O.P.+ 2,923 mm (32 mm increase since 7:00 on June 30)	O.P.+ 2,937 mm (62 mm increase since 7:00 on June 30)	O.P.+ 2,831 mm (17 mm decrease since 7:00 on June 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,558 mm (Increase from initial level:5,775 mm, 8 mm increase since 7:00 on June 30) O.P.+ 1,471 mm (Increase from initial level:2,197 mm, 510 mm decrease since 7:00 on June 30) O.P.+ 4,397 mm (Water level from floor:601 mm, 2 mm increase since 7:00 on June 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 11:17 on June 28 to 10:25 on June 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 11:22 on June 28 to 10:14 on June 30)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on June 30 to 15:00 on June 30)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:30 on June 23 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:48 on June 25 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.