

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 2)**

Water Level of the accumulated water (at 7:00 on July 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 796 mm (1 mm decrease since 7:00 on July 1)	O.P.+ 2,046 mm (91 mm decrease since 7:00 on July 1)	—
	Water level of Turbine Building	O.P.+ 2,615 mm (82 mm increase since 7:00 on July 1)	O.P.+ 2,893 mm (79 mm increase since 7:00 on July 1)	O.P.+ 2,873 mm (12 mm decrease since 7:00 on July 1)	O.P.+ 2,848 mm (7 mm increase since 7:00 on July 1)
	Water level of Reactor Building	O.P.+ 4,105 mm (26 mm increase since 7:00 on July 1)	O.P.+ 3,000 mm (77 mm increase since 7:00 on July 1)	O.P.+ 2,928 mm (9 mm decrease since 7:00 on July 1)	O.P.+ 2,837 mm (6 mm increase since 7:00 on July 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,562 mm (Increase from initial level:5,779 mm, 4 mm increase since 7:00 on July 1) O.P.+ 1,218 mm (Increase from initial level:1,944 mm, 253 mm decrease since 7:00 on July 1) O.P.+ 4,398 mm (Water level from floor:602 mm, 1 mm increase since 7:00 on July 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:27 on July 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:44 on July 1)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 1 to 15:00 on July 1)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:30 on June 23   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:20 on July 2   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.