

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 6)**

Water Level of the accumulated water (at 7:00 on July 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 796 mm (1 mm decrease since 7:00 on July 5)	O.P.+ 2,044 mm (No change since 7:00 on July 5)	—
	Water level of Turbine Building	O.P.+ 2,670 mm (13 mm increase since 7:00 on July 5)	O.P.+ 2,876 mm (67 mm increase since 7:00 on July 5)	O.P.+ 2,824 mm (42 mm increase since 7:00 on July 5)	O.P.+ 2,813 mm (11 mm decrease since 7:00 on July 5)
	Water level of Reactor Building	O.P.+ 4,112 mm (1 mm decrease since 7:00 on July 5)	O.P.+ 2,979 mm (17 mm increase since 7:00 on July 5)	O.P.+ 2,861 mm (42 mm increase since 7:00 on July 5)	O.P.+ 2,815 mm (7 mm decrease since 7:00 on July 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,577 mm (Increase from initial level:5,794 mm, 3 mm increase since 7:00 on July 5) O.P.+ 2,175 mm (Increase from initial level:2,901 mm, 446 mm decrease since 7:00 on July 5) O.P.+ 4,404 mm (Water level from floor:608 mm, 2 mm increase since 7:00 on July 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 11:27 on July 1 to 10:06 on July 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 11:44 on July 1 to 10:00 on July 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:30 on June 23 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:34 on July 2 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.