

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 10)**

Water Level of the accumulated water (at 7:00 on July 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 909 mm (31 mm increase since 7:00 on July 9)	O.P.+ 2,387 mm (3 mm decrease since 7:00 on July 9)	—
	Water level of Turbine Building	O.P.+ 2,722 mm (13 mm increase since 7:00 on July 9)	O.P.+ 2,863 mm (37 mm decrease since 7:00 on July 9)	O.P.+ 2,903 mm (41 mm decrease since 7:00 on July 9)	O.P.+ 2,853 mm (13 mm increase since 7:00 on July 9)
	Water level of Reactor Building	O.P.+ 4,138 mm (2 mm decrease since 7:00 on July 9)	O.P.+ 3,020 mm (31 mm decrease since 7:00 on July 9)	O.P.+ 2,971 mm (36 mm decrease since 7:00 on July 9)	O.P.+ 2,842 mm (11 mm increase since 7:00 on July 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,595 mm (Increase from initial level:5,812 mm, 2 mm increase since 7:00 on July 9) O.P.+ 1,910 mm (Increase from initial level:2,636 mm, 394 mm increase since 7:00 on July 9) O.P.+ 4,407 mm (Water level from floor:611 mm, No change since 7:00 on July 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:02 on July 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:19 on July 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:30 on June 23 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 15:45 on July 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.