

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 11)**

Water Level of the accumulated water (at 7:00 on July 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 928 mm (19 mm increase since 7:00 on July 10)	O.P.+ 2,386 mm (1 mm decrease since 7:00 on July 10)	—
	Water level of Turbine Building	O.P.+ 2,735 mm (13 mm increase since 7:00 on July 10)	O.P.+ 2,827 mm (36 mm decrease since 7:00 on July 10)	O.P.+ 2,866 mm (37 mm decrease since 7:00 on July 10)	O.P.+ 2,855 mm (2 mm increase since 7:00 on July 10)
	Water level of Reactor Building	O.P.+ 4,130 mm (8 mm decrease since 7:00 on July 10)	O.P.+ 2,987 mm (33 mm decrease since 7:00 on July 10)	O.P.+ 2,924 mm (47 mm decrease since 7:00 on July 10)	O.P.+ 2,845 mm (3 mm increase since 7:00 on July 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,441 mm (Increase from initial level:5,658 mm, 154 mm decrease since 7:00 on July 10) O.P.+ 2,400 mm (Increase from initial level:3,126 mm, 490 mm increase since 7:00 on July 10) O.P.+ 4,409 mm (Water level from floor:613 mm, 2 mm increase since 7:00 on July 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:02 on July 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:19 on July 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:22 on July 10 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:45 on July 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.