

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 12)**

Water Level of the accumulated water (at 7:00 on July 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 943 mm (15 mm increase since 7:00 on July 11)	O.P.+ 2,384 mm (2 mm decrease since 7:00 on July 11)	—
	Water level of Turbine Building	O.P.+ 2,747 mm (12 mm increase since 7:00 on July 11)	O.P.+ 2,795 mm (32 mm decrease since 7:00 on July 11)	O.P.+ 2,895 mm (29 mm increase since 7:00 on July 11)	O.P.+ 2,853 mm (2 mm decrease since 7:00 on July 11)
	Water level of Reactor Building	O.P.+ 4,116 mm (14 mm decrease since 7:00 on July 11)	O.P.+ 2,958 mm (29 mm decrease since 7:00 on July 11)	O.P.+ 2,952 mm (28 mm increase since 7:00 on July 11)	O.P.+ 2,843 mm (2 mm decrease since 7:00 on July 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,274 mm (Increase from initial level:5,491 mm, 167 mm decrease since 7:00 on July 11) O.P.+ 2,481 mm (Increase from initial level:3,207 mm, 81 mm increase since 7:00 on July 11) O.P.+ 4,409 mm (Water level from floor:613 mm, No change since 7:00 on July 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:02 on July 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:19 on July 9 to 9:51 on July 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:22 on July 10 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:45 on July 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.