

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 13)**

Water Level of the accumulated water (at 7:00 on July 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 949 mm (6 mm increase since 7:00 on July 12)	O.P.+ 2,384 mm (No change since 7:00 on July 12)	—
	Water level of Turbine Building	O.P.+ 2,548 mm (199 mm decrease since 7:00 on July 12)	O.P.+ 2,765 mm (30 mm decrease since 7:00 on July 12)	O.P.+ 2,918 mm (23 mm increase since 7:00 on July 12)	O.P.+ 2,863 mm (10 mm increase since 7:00 on July 12)
	Water level of Reactor Building	O.P.+ 4,100 mm (16 mm decrease since 7:00 on July 12)	O.P.+ 2,928 mm (30 mm decrease since 7:00 on July 12)	O.P.+ 2,977 mm (25 mm increase since 7:00 on July 12)	O.P.+ 2,850 mm (7 mm increase since 7:00 on July 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,134 mm (Increase from initial level:5,351 mm, 140 mm decrease since 7:00 on July 12) O.P.+ 2,509 mm (Increase from initial level:3,235 mm, 28 mm increase since 7:00 on July 12) O.P.+ 4,412 mm (Water level from floor:616 mm, 3 mm increase since 7:00 on July 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 10:07 on July 12 to 16:12 on July 12)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:02 on July 7)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:22 on July 10 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 15:45 on July 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.