

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 17)**

Water Level of the accumulated water (at 7:00 on July 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,754 mm (719 mm increase since 7:00 on July 16)	O.P.+ 2,127 mm (13 mm increase since 7:00 on July 16)	—
	Water level of Turbine Building	O.P.+ 2,701 mm (50 mm increase since 7:00 on July 16)	O.P.+ 2,745 mm (41 mm increase since 7:00 on July 16)	O.P.+ 2,984 mm (81 mm increase since 7:00 on July 16)	O.P.+ 2,877 mm (21 mm increase since 7:00 on July 16)
	Water level of Reactor Building	O.P.+ 4,487 mm (447 mm increase since 7:00 on July 16)	O.P.+ 2,935 mm (78 mm increase since 7:00 on July 16)	O.P.+ 3,052 mm (98 mm increase since 7:00 on July 16)	O.P.+ 2,864 mm (17 mm increase since 7:00 on July 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,022 mm (Increase from initial level:5,239 mm, 11 mm increase since 7:00 on July 16) O.P.+ 3,522 mm (Increase from initial level:4,248 mm, 222 mm decrease since 7:00 on July 16) O.P.+ 4,425 mm (Water level from floor:629 mm, 10 mm increase since 7:00 on July 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:02 on July 7)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 16 to 15:00 on July 16)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:52 on July 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.