

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 18)**

Water Level of the accumulated water (at 7:00 on July 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,813 mm (59 mm increase since 7:00 on July 17)	O.P.+ 2,130 mm (3 mm increase since 7:00 on July 17)	—
	Water level of Turbine Building	O.P.+ 2,743 mm (42 mm increase since 7:00 on July 17)	O.P.+ 2,753 mm (8 mm increase since 7:00 on July 17)	O.P.+ 2,944 mm (40 mm decrease since 7:00 on July 17)	O.P.+ 2,893 mm (16 mm increase since 7:00 on July 17)
	Water level of Reactor Building	O.P.+ 4,598 mm (111 mm increase since 7:00 on July 17)	O.P.+ 2,936 mm (1 mm increase since 7:00 on July 17)	O.P.+ 3,007 mm (45 mm decrease since 7:00 on July 17)	O.P.+ 2,879 mm (15 mm increase since 7:00 on July 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,382 mm (Increase from initial level:5,599 mm, 360 mm increase since 7:00 on July 17) O.P.+ 2,865 mm (Increase from initial level:3,591 mm, 657 mm decrease since 7:00 on July 17) O.P.+ 4,429 mm (Water level from floor:633 mm, 4 mm increase since 7:00 on July 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:43 on July 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:26 on July 17)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 17 to 15:00 on July 17)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:52 on July 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.