

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 19)**

Water Level of the accumulated water (at 7:00 on July 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,831 mm (18 mm increase since 7:00 on July 18)	O.P.+ 2,131 mm (1 mm increase since 7:00 on July 18)	—
	Water level of Turbine Building	O.P.+ 2,783 mm (40 mm increase since 7:00 on July 18)	O.P.+ 2,740 mm (13 mm decrease since 7:00 on July 18)	O.P.+ 2,899 mm (45 mm decrease since 7:00 on July 18)	O.P.+ 2,896 mm (3 mm increase since 7:00 on July 18)
	Water level of Reactor Building	O.P.+ 4,631 mm (33 mm increase since 7:00 on July 18)	O.P.+ 2,908 mm (28 mm decrease since 7:00 on July 18)	O.P.+ 2,956 mm (51 mm decrease since 7:00 on July 18)	O.P.+ 2,879 mm (No change since 7:00 on July 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,834 mm (Increase from initial level:6,051 mm, 452 mm increase since 7:00 on July 18) O.P.+ 2,319 mm (Increase from initial level:3,045 mm, 546 mm decrease since 7:00 on July 18) O.P.+ 4,431 mm (Water level from floor:635 mm, 2 mm increase since 7:00 on July 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:43 on July 17)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:26 on July 17)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 17 to 15:00 on July 17)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:52 on July 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.