

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 20)**

Water Level of the accumulated water (at 7:00 on July 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,831 mm (No change since 7:00 on July 19)	O.P.+ 2,131 mm (No change since 7:00 on July 19)	—
	Water level of Turbine Building	O.P.+ 2,783 mm (No change since 7:00 on July 19)	O.P.+ 2,740 mm (No change since 7:00 on July 19)	O.P.+ 2,899 mm (No change since 7:00 on July 19)	O.P.+ 2,896 mm (No change since 7:00 on July 19)
	Water level of Reactor Building	O.P.+ 4,631 mm (No change since 7:00 on July 19)	O.P.+ 2,908 mm (No change since 7:00 on July 19)	O.P.+ 2,956 mm (No change since 7:00 on July 19)	O.P.+ 2,879 mm (No change since 7:00 on July 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,834 mm (Increase from initial level:6,051 mm, No change since 7:00 on July 19) O.P.+ 2,319 mm (Increase from initial level:3,045 mm, No change since 7:00 on July 19) O.P.+ 4,433 mm (Water level from floor:637 mm, 2 mm increase since 7:00 on July 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 9:57 on July 19 to 16:50 on July 19)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on July 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:18 on July 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:52 on July 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.