

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 21)**

Water Level of the accumulated water (at 7:00 on July 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,890 mm (59 mm increase since 7:00 on July 20)	O.P.+ 2,137 mm (6 mm increase since 7:00 on July 20)	—
	Water level of Turbine Building	O.P.+ 2,620 mm (163 mm decrease since 7:00 on July 20)	O.P.+ 2,727 mm (13 mm decrease since 7:00 on July 20)	O.P.+ 2,852 mm (47 mm decrease since 7:00 on July 20)	O.P.+ 2,880 mm (16 mm decrease since 7:00 on July 20)
	Water level of Reactor Building	O.P.+ 4,679 mm (48 mm increase since 7:00 on July 20)	O.P.+ 2,900 mm (8 mm decrease since 7:00 on July 20)	O.P.+ 2,899 mm (57 mm decrease since 7:00 on July 20)	O.P.+ 2,870 mm (9 mm decrease since 7:00 on July 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,890 mm (Increase from initial level:6,107 mm, 56 mm increase since 7:00 on July 20) O.P.+ 3,343 mm (Increase from initial level:4,069 mm, 1,024 mm increase since 7:00 on July 20) O.P.+ 4,434 mm (Water level from floor:638 mm, 1 mm increase since 7:00 on July 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:14 on July 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:18 on July 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:52 on July 15   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.