

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 22)**

Water Level of the accumulated water (at 7:00 on July 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,895 mm (5 mm increase since 7:00 on July 21)	O.P.+ 1,619 mm (518 mm decrease since 7:00 on July 21)	—
	Water level of Turbine Building	O.P.+ 2,657 mm (37 mm increase since 7:00 on July 21)	O.P.+ 2,821 mm (94 mm increase since 7:00 on July 21)	O.P.+ 2,908 mm (56 mm increase since 7:00 on July 21)	O.P.+ 2,874 mm (6 mm decrease since 7:00 on July 21)
	Water level of Reactor Building	O.P.+ 4,649 mm (30 mm decrease since 7:00 on July 21)	O.P.+ 2,933 mm (33 mm increase since 7:00 on July 21)	O.P.+ 2,960 mm (61 mm increase since 7:00 on July 21)	O.P.+ 2,863 mm (7 mm decrease since 7:00 on July 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,891 mm (Increase from initial level:6,108 mm, 1 mm increase since 7:00 on July 21) O.P.+ 2,895 mm (Increase from initial level:3,621 mm, 448 mm decrease since 7:00 on July 21) O.P.+ 4,436 mm (Water level from floor:640 mm, 2 mm increase since 7:00 on July 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 6:22 on July 22)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:18 on July 19 to 10:04 on July 21)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 21 to 15:00 on July 21)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:52 on July 15 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.