

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 23)**

Water Level of the accumulated water (at 7:00 on July 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,897 mm (2 mm increase since 7:00 on July 22)	O.P.+ 1,622 mm (3 mm increase since 7:00 on July 22)	—
	Water level of Turbine Building	O.P.+ 2,758 mm (101 mm increase since 7:00 on July 22)	O.P.+ 2,800 mm (21 mm decrease since 7:00 on July 22)	O.P.+ 2,939 mm (31 mm increase since 7:00 on July 22)	O.P.+ 2,883 mm (9 mm increase since 7:00 on July 22)
	Water level of Reactor Building	O.P.+ 4,615 mm (34 mm decrease since 7:00 on July 22)	O.P.+ 2,955 mm (22 mm increase since 7:00 on July 22)	O.P.+ 2,997 mm (37 mm increase since 7:00 on July 22)	O.P.+ 2,873 mm (10 mm increase since 7:00 on July 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,894 mm (Increase from initial level:6,111 mm, 3 mm increase since 7:00 on July 22) O.P.+ 3,019 mm (Increase from initial level:3,745 mm, 124 mm increase since 7:00 on July 22) O.P.+ 4,437 mm (Water level from floor:641 mm, 1 mm increase since 7:00 on July 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 6:22 on July 22)		—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 22 to 15:00 on July 22)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:31 on July 23 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.