

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 26)**

Water Level of the accumulated water (at 7:00 on July 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,901 mm (3 mm increase since 7:00 on July 25)	O.P.+ 1,488 mm (3 mm increase since 7:00 on July 25)	—
	Water level of Turbine Building	O.P.+ 2,853 mm (30 mm increase since 7:00 on July 25)	O.P.+ 2,898 mm (91 mm increase since 7:00 on July 25)	O.P.+ 2,973 mm (28 mm increase since 7:00 on July 25)	O.P.+ 2,914 mm (12 mm increase since 7:00 on July 25)
	Water level of Reactor Building	O.P.+ 4,518 mm (26 mm decrease since 7:00 on July 25)	O.P.+ 2,998 mm (65 mm increase since 7:00 on July 25)	O.P.+ 3,040 mm (36 mm increase since 7:00 on July 25)	O.P.+ 2,894 mm (8 mm increase since 7:00 on July 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,900 mm (Increase from initial level:6,117 mm, 1 mm increase since 7:00 on July 25) O.P.+ 2,678 mm (Increase from initial level:3,404 mm, 701 mm decrease since 7:00 on July 25) O.P.+ 4,440 mm (Water level from floor:644 mm, 1 mm increase since 7:00 on July 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:15 on July 23 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.