

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 28)**

Water Level of the accumulated water (at 7:00 on July 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,899 mm (2 mm decrease since 7:00 on July 27)	O.P.+ 1,499 mm (8 mm increase since 7:00 on July 27)	—
	Water level of Turbine Building	O.P.+ 2,909 mm (27 mm increase since 7:00 on July 27)	O.P.+ 3,062 mm (79 mm increase since 7:00 on July 27)	O.P.+ 3,018 mm (22 mm increase since 7:00 on July 27)	O.P.+ 2,940 mm (13 mm increase since 7:00 on July 27)
	Water level of Reactor Building	O.P.+ 4,504 mm (2 mm decrease since 7:00 on July 27)	O.P.+ 3,161 mm (78 mm increase since 7:00 on July 27)	O.P.+ 3,089 mm (23 mm increase since 7:00 on July 27)	O.P.+ 2,913 mm (10 mm increase since 7:00 on July 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,902 mm (Increase from initial level:6,119 mm, 1 mm increase since 7:00 on July 27) O.P.+ 1,545 mm (Increase from initial level:2,271 mm, 566 mm decrease since 7:00 on July 27) O.P.+ 4,442 mm (Water level from floor:646 mm, No change since 7:00 on July 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building Temporary TankTransfer Completed(From 10:00 on July 27 to 15:00 on July 27)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:27 on July 28 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.