

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 30)**

Water Level of the accumulated water (at 7:00 on July 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,900 mm (No change since 7:00 on July 29)	O.P.+ 1,548 mm (50 mm increase since 7:00 on July 29)	—
	Water level of Turbine Building	O.P.+ 2,683 mm (227 mm decrease since 7:00 on July 29)	O.P.+ 3,061 mm (24 mm decrease since 7:00 on July 29)	O.P.+ 2,978 mm (22 mm decrease since 7:00 on July 29)	O.P.+ 2,955 mm (2 mm increase since 7:00 on July 29)
	Water level of Reactor Building	O.P.+ 4,505 mm (3 mm decrease since 7:00 on July 29)	O.P.+ 3,200 mm (16 mm decrease since 7:00 on July 29)	O.P.+ 3,046 mm (33 mm decrease since 7:00 on July 29)	O.P.+ 2,931 mm (8 mm increase since 7:00 on July 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,911 mm (Increase from initial level:6,128 mm, 5 mm increase since 7:00 on July 29) O.P.+ 1,934 mm (Increase from initial level:2,660 mm, 354 mm increase since 7:00 on July 29) O.P.+ 4,445 mm (Water level from floor:649 mm, 1 mm increase since 7:00 on July 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 5:54 on July 29 to 13:48 on July 29)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 19:23 on July 28 to 5:00 on July 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 19:38 on July 28 to 4:55 on July 30)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 29 to 15:00 on July 29)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:28 on July 30   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.