

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on July 31)**

Water Level of the accumulated water (at 7:00 on July 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,904 mm (4 mm increase since 7:00 on July 30)	O.P.+ 3,020 mm (1,472 mm increase since 7:00 on July 30)	—
	Water level of Turbine Building	O.P.+ 2,776 mm (93 mm increase since 7:00 on July 30)	O.P.+ 3,091 mm (30 mm increase since 7:00 on July 30)	O.P.+ 3,018 mm (40 mm increase since 7:00 on July 30)	O.P.+ 2,961 mm (6 mm increase since 7:00 on July 30)
	Water level of Reactor Building	O.P.+ 4,504 mm (1 mm decrease since 7:00 on July 30)	O.P.+ 3,222 mm (22 mm increase since 7:00 on July 30)	O.P.+ 3,090 mm (44 mm increase since 7:00 on July 30)	O.P.+ 2,934 mm (3 mm increase since 7:00 on July 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,917 mm (Increase from initial level:6,134 mm, 6 mm increase since 7:00 on July 30) O.P.+ 1,695 mm (Increase from initial level:2,421 mm, 239 mm decrease since 7:00 on July 30) O.P.+ 4,447 mm (Water level from floor:651 mm, 2 mm increase since 7:00 on July 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
			Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)		
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 30 to 15:00 on July 30)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:34 on July 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.