

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 1)**

Water Level of the accumulated water (at 7:00 on August 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,906 mm (2 mm increase since 7:00 on July 31)	O.P.+ 3,040 mm (20 mm increase since 7:00 on July 31)	—
	Water level of Turbine Building	O.P.+ 2,809 mm (33 mm increase since 7:00 on July 31)	O.P.+ 3,075 mm (16 mm decrease since 7:00 on July 31)	O.P.+ 3,043 mm (25 mm increase since 7:00 on July 31)	O.P.+ 2,974 mm (13 mm increase since 7:00 on July 31)
	Water level of Reactor Building	O.P.+ 4,500 mm (4 mm decrease since 7:00 on July 31)	O.P.+ 3,217 mm (5 mm decrease since 7:00 on July 31)	O.P.+ 3,120 mm (30 mm increase since 7:00 on July 31)	O.P.+ 2,943 mm (9 mm increase since 7:00 on July 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,927 mm (Increase from initial level:6,144 mm, 10 mm increase since 7:00 on July 31) O.P.+ 1,563 mm (Increase from initial level:2,289 mm, 132 mm decrease since 7:00 on July 31) O.P.+ 4,448 mm (Water level from floor:652 mm, 1 mm increase since 7:00 on July 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
			Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)		
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on July 31 to 15:00 on July 31)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:34 on July 30   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.