

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 2)**

Water Level of the accumulated water (at 7:00 on August 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,908 mm (2 mm increase since 7:00 on August 1)	O.P.+ 3,020 mm (20 mm decrease since 7:00 on August 1)	—
	Water level of Turbine Building	O.P.+ 2,835 mm (26 mm increase since 7:00 on August 1)	O.P.+ 3,057 mm (18 mm decrease since 7:00 on August 1)	O.P.+ 3,011 mm (32 mm decrease since 7:00 on August 1)	O.P.+ 2,983 mm (9 mm increase since 7:00 on August 1)
	Water level of Reactor Building	O.P.+ 4,491 mm (9 mm decrease since 7:00 on August 1)	O.P.+ 3,205 mm (12 mm decrease since 7:00 on August 1)	O.P.+ 3,090 mm (30 mm decrease since 7:00 on August 1)	O.P.+ 2,953 mm (10 mm increase since 7:00 on August 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,932 mm (Increase from initial level:6,149 mm, 5 mm increase since 7:00 on August 1) O.P.+ 1,786 mm (Increase from initial level:2,512 mm, 223 mm increase since 7:00 on August 1) O.P.+ 4,449 mm (Water level from floor:653 mm, 1 mm increase since 7:00 on August 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:15 on August 1)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:34 on July 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.