

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 3)**

| | | | | | |
|--|--|---|--|--|--|
| Water Level of the accumulated water (at 7:00 on August 3) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 1,913 mm (5 mm increase since 7:00 on August 2) | O.P.+ 3,000 mm (20 mm decrease since 7:00 on August 2) | — |
| | Water level of Turbine Building | O.P.+ 2,860 mm (25 mm increase since 7:00 on August 2) | O.P.+ 3,041 mm (16 mm decrease since 7:00 on August 2) | O.P.+ 3,003 mm (8 mm decrease since 7:00 on August 2) | O.P.+ 2,979 mm (4 mm decrease since 7:00 on August 2) |
| | Water level of Reactor Building | O.P.+ 4,478 mm (13 mm decrease since 7:00 on August 2) | O.P.+ 3,191 mm (14 mm decrease since 7:00 on August 2) | O.P.+ 3,070 mm (20 mm decrease since 7:00 on August 2) | O.P.+ 2,955 mm (2 mm increase since 7:00 on August 2) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,935 mm (Increase from initial level:6,152 mm, 3 mm increase since 7:00 on August 2) O.P.+ 1,992 mm (Increase from initial level:2,718 mm, 206 mm increase since 7:00 on August 2) O.P.+ 4,450 mm (Water level from floor:654 mm, 1 mm increase since 7:00 on August 2) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 14:15 on August 1 to 21:52 on August 2) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:34 on July 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.