

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 4)**

Water Level of the accumulated water (at 7:00 on August 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,947 mm (34 mm increase since 7:00 on August 3)	O.P.+ 3,030 mm (30 mm increase since 7:00 on August 3)	—
	Water level of Turbine Building	O.P.+ 2,882 mm (22 mm increase since 7:00 on August 3)	O.P.+ 3,026 mm (15 mm decrease since 7:00 on August 3)	O.P.+ 3,035 mm (32 mm increase since 7:00 on August 3)	O.P.+ 2,983 mm (4 mm increase since 7:00 on August 3)
	Water level of Reactor Building	O.P.+ 4,467 mm (11 mm decrease since 7:00 on August 3)	O.P.+ 3,172 mm (19 mm decrease since 7:00 on August 3)	O.P.+ 3,110 mm (40 mm increase since 7:00 on August 3)	O.P.+ 2,957 mm (2 mm increase since 7:00 on August 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,939 mm (Increase from initial level:6,156 mm, 4 mm increase since 7:00 on August 3) O.P.+ 1,875 mm (Increase from initial level:2,601 mm, 117 mm decrease since 7:00 on August 3) O.P.+ 4,451 mm (Water level from floor:655 mm, 1 mm increase since 7:00 on August 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on August 3 to 15:00 on August 3)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:34 on July 30   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.