

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 5)**

Water Level of the accumulated water (at 7:00 on August 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 795 mm (1,152 mm decrease since 7:00 on August 4)	O.P.+ 3,060 mm (30 mm increase since 7:00 on August 4)	—
	Water level of Turbine Building	O.P.+ 2,898 mm (16 mm increase since 7:00 on August 4)	O.P.+ 3,017 mm (9 mm decrease since 7:00 on August 4)	O.P.+ 3,057 mm (22 mm increase since 7:00 on August 4)	O.P.+ 2,997 mm (14 mm increase since 7:00 on August 4)
	Water level of Reactor Building	O.P.+ 4,437 mm (30 mm decrease since 7:00 on August 4)	O.P.+ 3,163 mm (9 mm decrease since 7:00 on August 4)	O.P.+ 3,134 mm (24 mm increase since 7:00 on August 4)	O.P.+ 2,967 mm (10 mm increase since 7:00 on August 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,949 mm (Increase from initial level:6,166 mm, 10 mm increase since 7:00 on August 4) O.P.+ 1,759 mm (Increase from initial level:2,485 mm, 116 mm decrease since 7:00 on August 4) O.P.+ 4,453 mm (Water level from floor:657 mm, 3 mm increase since 7:00 on August 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:34 on July 30   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.