

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 6)**

Water Level of the accumulated water (at 7:00 on August 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 822 mm (27 mm increase since 7:00 on August 5)	O.P.+ 3,090 mm (30 mm increase since 7:00 on August 5)	—
	Water level of Turbine Building	O.P.+ 2,920 mm (22 mm increase since 7:00 on August 5)	O.P.+ 3,006 mm (11 mm decrease since 7:00 on August 5)	O.P.+ 3,078 mm (21 mm increase since 7:00 on August 5)	O.P.+ 3,008 mm (11 mm increase since 7:00 on August 5)
	Water level of Reactor Building	O.P.+ 4,424 mm (13 mm decrease since 7:00 on August 5)	O.P.+ 3,147 mm (16 mm decrease since 7:00 on August 5)	O.P.+ 3,163 mm (29 mm increase since 7:00 on August 5)	O.P.+ 2,973 mm (6 mm increase since 7:00 on August 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,960 mm (Increase from initial level:6,177 mm, 11 mm increase since 7:00 on August 5) O.P.+ 1,644 mm (Increase from initial level:2,370 mm, 115 mm decrease since 7:00 on August 5) O.P.+ 4,454 mm (Water level from floor:658 mm, 1 mm increase since 7:00 on August 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on August 5 to 15:00 on August 5)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:44 on August 6   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.