

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 7)**

Water Level of the accumulated water (at 7:00 on August 7)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 986 mm (164 mm increase since 7:00 on August 6)	O.P.+ 3,110 mm (20 mm increase since 7:00 on August 6)	—
	Water level of Turbine Building	O.P.+ 2,938 mm (18 mm increase since 7:00 on August 6)	O.P.+ 2,993 mm (13 mm decrease since 7:00 on August 6)	O.P.+ 3,104 mm (26 mm increase since 7:00 on August 6)	O.P.+ 3,021 mm (13 mm increase since 7:00 on August 6)
	Water level of Reactor Building	O.P.+ 4,385 mm (39 mm decrease since 7:00 on August 6)	O.P.+ 3,134 mm (13 mm decrease since 7:00 on August 6)	O.P.+ 3,191 mm (28 mm increase since 7:00 on August 6)	O.P.+ 2,986 mm (13 mm increase since 7:00 on August 6)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,970 mm (Increase from initial level:6,187 mm, 10 mm increase since 7:00 on August 6) O.P.+ 1,616 mm (Increase from initial level:2,342 mm, 28 mm decrease since 7:00 on August 6) O.P.+ 4,456 mm (Water level from floor:660 mm, 2 mm increase since 7:00 on August 6)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:21 on August 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.