

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 8)**

Water Level of the accumulated water (at 7:00 on August 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,006 mm (20 mm increase since 7:00 on August 7)	O.P.+ - mm #VALUE!	—
	Water level of Turbine Building	O.P.+ 2,929 mm (9 mm decrease since 7:00 on August 7)	O.P.+ 2,977 mm (16 mm decrease since 7:00 on August 7)	O.P.+ 3,125 mm (21 mm increase since 7:00 on August 7)	O.P.+ 3,033 mm (12 mm increase since 7:00 on August 7)
	Water level of Reactor Building	O.P.+ 4,372 mm (13 mm decrease since 7:00 on August 7)	O.P.+ 3,120 mm (14 mm decrease since 7:00 on August 7)	O.P.+ 3,217 mm (26 mm increase since 7:00 on August 7)	O.P.+ 2,993 mm (7 mm increase since 7:00 on August 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,986 mm (Increase from initial level:6,203 mm, 16 mm increase since 7:00 on August 7) O.P.+ 1,473 mm (Increase from initial level:2,199 mm, 143 mm decrease since 7:00 on August 7) O.P.+ 4,457 mm (Water level from floor:661 mm, 1 mm increase since 7:00 on August 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 6:04 on August 8)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on August 7 to 15:00 on August 7)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:21 on August 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.