

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 9)**

Water Level of the accumulated water (at 7:00 on August 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,024 mm (18 mm increase since 7:00 on August 8)	O.P.+ 3,100 mm	—
	Water level of Turbine Building	O.P.+ 2,558 mm (371 mm decrease since 7:00 on August 8)	O.P.+ 2,961 mm (16 mm decrease since 7:00 on August 8)	O.P.+ 3,089 mm (36 mm decrease since 7:00 on August 8)	O.P.+ 3,046 mm (13 mm increase since 7:00 on August 8)
	Water level of Reactor Building	O.P.+ 4,360 mm (12 mm decrease since 7:00 on August 8)	O.P.+ 3,112 mm (8 mm decrease since 7:00 on August 8)	O.P.+ 3,188 mm (29 mm decrease since 7:00 on August 8)	O.P.+ 3,007 mm (14 mm increase since 7:00 on August 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,988 mm (Increase from initial level:6,205 mm, 2 mm increase since 7:00 on August 8) O.P.+ 1,669 mm (Increase from initial level:2,395 mm, 196 mm increase since 7:00 on August 8) O.P.+ 4,458 mm (Water level from floor:662 mm, 1 mm increase since 7:00 on August 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 6:04 on August 8 to 17:52 on August 8)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:43 on August 8)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on August 7 to 15:00 on August 7)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:21 on August 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.