

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 10)**

Water Level of the accumulated water (at 7:00 on August 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,040 mm (16 mm increase since 7:00 on August 9)	O.P.+ 3,090 mm (10 mm decrease since 7:00 on August 9)	—
	Water level of Turbine Building	O.P.+ 2,575 mm (17 mm increase since 7:00 on August 9)	O.P.+ 2,949 mm (12 mm decrease since 7:00 on August 9)	O.P.+ 3,074 mm (15 mm decrease since 7:00 on August 9)	O.P.+ 3,044 mm (2 mm decrease since 7:00 on August 9)
	Water level of Reactor Building	O.P.+ 4,344 mm (16 mm decrease since 7:00 on August 9)	O.P.+ 3,104 mm (8 mm decrease since 7:00 on August 9)	O.P.+ 3,156 mm (32 mm decrease since 7:00 on August 9)	O.P.+ 3,015 mm (8 mm increase since 7:00 on August 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,988 mm (Increase from initial level:6,205 mm, No change since 7:00 on August 9) O.P.+ 1,871 mm (Increase from initial level:2,597 mm, 202 mm increase since 7:00 on August 9) O.P.+ 4,459 mm (Water level from floor:663 mm, 1 mm increase since 7:00 on August 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:59 on July 30)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 14:43 on August 8 to 22:11 on August 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:21 on August 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.