

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 11)**

Water Level of the accumulated water (at 7:00 on August 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,053 mm (13 mm increase since 7:00 on August 10)	O.P.+ 3,110 mm (20 mm increase since 7:00 on August 10)	—
	Water level of Turbine Building	O.P.+ 2,594 mm (19 mm increase since 7:00 on August 10)	O.P.+ 2,995 mm (46 mm increase since 7:00 on August 10)	O.P.+ 3,103 mm (29 mm increase since 7:00 on August 10)	O.P.+ 3,050 mm (6 mm increase since 7:00 on August 10)
	Water level of Reactor Building	O.P.+ 4,334 mm (10 mm decrease since 7:00 on August 10)	O.P.+ 3,112 mm (8 mm increase since 7:00 on August 10)	O.P.+ 3,190 mm (34 mm increase since 7:00 on August 10)	O.P.+ 3,020 mm (5 mm increase since 7:00 on August 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,991 mm (Increase from initial level:6,208 mm, 3 mm increase since 7:00 on August 10) O.P.+ 1,482 mm (Increase from initial level:2,208 mm, 389 mm decrease since 7:00 on August 10) O.P.+ 4,462 mm (Water level from floor:666 mm, 3 mm increase since 7:00 on August 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 18:59 on July 30 to 16:58 on August 10)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:21 on August 6 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.