

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 12)**

Water Level of the accumulated water (at 7:00 on August 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,064 mm (11 mm increase since 7:00 on August 11)	O.P.+ 3,100 mm (10 mm decrease since 7:00 on August 11)	—
	Water level of Turbine Building	O.P.+ 2,610 mm (16 mm increase since 7:00 on August 11)	O.P.+ 3,019 mm (24 mm increase since 7:00 on August 11)	O.P.+ 3,082 mm (21 mm decrease since 7:00 on August 11)	O.P.+ 3,057 mm (7 mm increase since 7:00 on August 11)
	Water level of Reactor Building	O.P.+ 4,332 mm (2 mm decrease since 7:00 on August 11)	O.P.+ 3,154 mm (42 mm increase since 7:00 on August 11)	O.P.+ 3,175 mm (15 mm decrease since 7:00 on August 11)	O.P.+ 3,027 mm (7 mm increase since 7:00 on August 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,996 mm (Increase from initial level:6,213 mm, 5 mm increase since 7:00 on August 11) O.P.+ 1,396 mm (Increase from initial level:2,122 mm, 86 mm decrease since 7:00 on August 11) O.P.+ 4,462 mm (Water level from floor:666 mm, No change since 7:00 on August 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:37 on August 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:21 on August 12   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.