

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 13)**

Water Level of the accumulated water (at 7:00 on August 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,073 mm (9 mm increase since 7:00 on August 12)	O.P.+ 3,070 mm (30 mm decrease since 7:00 on August 12)	—
	Water level of Turbine Building	O.P.+ 2,625 mm (15 mm increase since 7:00 on August 12)	O.P.+ 2,998 mm (21 mm decrease since 7:00 on August 12)	O.P.+ 3,039 mm (43 mm decrease since 7:00 on August 12)	O.P.+ 3,051 mm (6 mm decrease since 7:00 on August 12)
	Water level of Reactor Building	O.P.+ 4,328 mm (4 mm decrease since 7:00 on August 12)	O.P.+ 3,144 mm (10 mm decrease since 7:00 on August 12)	O.P.+ 3,126 mm (49 mm decrease since 7:00 on August 12)	O.P.+ 3,027 mm (No change since 7:00 on August 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,999 mm (Increase from initial level:6,216 mm, 3 mm increase since 7:00 on August 12) O.P.+ 1,984 mm (Increase from initial level:2,710 mm, 588 mm increase since 7:00 on August 12) O.P.+ 4,463 mm (Water level from floor:667 mm, 1 mm increase since 7:00 on August 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:37 on August 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:28 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.