

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 14)**

Water Level of the accumulated water (at 7:00 on August 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,113 mm (40 mm increase since 7:00 on August 13)	O.P.+ 3,040 mm (30 mm decrease since 7:00 on August 13)	—
	Water level of Turbine Building	O.P.+ 2,640 mm (15 mm increase since 7:00 on August 13)	O.P.+ 2,983 mm (15 mm decrease since 7:00 on August 13)	O.P.+ 3,008 mm (31 mm decrease since 7:00 on August 13)	O.P.+ 3,038 mm (13 mm decrease since 7:00 on August 13)
	Water level of Reactor Building	O.P.+ 4,352 mm (24 mm increase since 7:00 on August 13)	O.P.+ 3,134 mm (10 mm decrease since 7:00 on August 13)	O.P.+ 3,089 mm (37 mm decrease since 7:00 on August 13)	O.P.+ 3,018 mm (9 mm decrease since 7:00 on August 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,001 mm (Increase from initial level:6,218 mm, 2 mm increase since 7:00 on August 13) O.P.+ 2,390 mm (Increase from initial level:3,116 mm, 406 mm increase since 7:00 on August 13) O.P.+ 4,465 mm (Water level from floor:669 mm, 2 mm increase since 7:00 on August 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:37 on August 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:28 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.