

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 16)**

| | | | | | |
|--|--|---|--|---|--|
| Water Level of the accumulated water (at 7:00 on August 16) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 1,143 mm (10 mm increase since 7:00 on August 15) | O.P.+ 3,040 mm (20 mm increase since 7:00 on August 15) | — |
| | Water level of Turbine Building | O.P.+ 2,646 mm (10 mm decrease since 7:00 on August 15) | O.P.+ 2,952 mm (19 mm decrease since 7:00 on August 15) | O.P.+ 3,026 mm (45 mm increase since 7:00 on August 15) | O.P.+ 3,010 mm (13 mm decrease since 7:00 on August 15) |
| | Water level of Reactor Building | O.P.+ 4,354 mm (11 mm decrease since 7:00 on August 15) | O.P.+ 3,093 mm (21 mm decrease since 7:00 on August 15) | O.P.+ 3,101 mm (45 mm increase since 7:00 on August 15) | O.P.+ 2,994 mm (11 mm decrease since 7:00 on August 15) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 5,004 mm (Increase from initial level:6,221 mm, 1 mm increase since 7:00 on August 15) O.P.+ 2,779 mm (Increase from initial level:3,505 mm, 27 mm decrease since 7:00 on August 15) O.P.+ 4,468 mm (Water level from floor:672 mm, 2 mm increase since 7:00 on August 15) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | Basement of Unit 1 Turbine Building → Currently being transferred (Since 5:56 on August 16) | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11) | Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 18:37 on August 11 to 10:03 on August 15) | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:28 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.