

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 17)**

Water Level of the accumulated water (at 7:00 on August 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,153 mm (10 mm increase since 7:00 on August 16)	O.P.+ 3,070 mm (30 mm increase since 7:00 on August 16)	—
	Water level of Turbine Building	O.P.+ 2,336 mm (310 mm decrease since 7:00 on August 16)	O.P.+ 2,942 mm (10 mm decrease since 7:00 on August 16)	O.P.+ 3,069 mm (43 mm increase since 7:00 on August 16)	O.P.+ 3,011 mm (1 mm increase since 7:00 on August 16)
	Water level of Reactor Building	O.P.+ 4,339 mm (15 mm decrease since 7:00 on August 16)	O.P.+ 3,083 mm (10 mm decrease since 7:00 on August 16)	O.P.+ 3,139 mm (38 mm increase since 7:00 on August 16)	O.P.+ 2,993 mm (1 mm decrease since 7:00 on August 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,006 mm (Increase from initial level:6,223 mm, 2 mm increase since 7:00 on August 16) O.P.+ 2,687 mm (Increase from initial level:3,413 mm, 92 mm decrease since 7:00 on August 16) O.P.+ 4,469 mm (Water level from floor:673 mm, 1 mm increase since 7:00 on August 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 5:56 on August 16 to 15:53 on August 16)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:28 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.