

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 18)**

Water Level of the accumulated water (at 7:00 on August 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,237 mm (84 mm increase since 7:00 on August 17)	O.P.+ 3,070 mm (No change since 7:00 on August 17)	—
	Water level of Turbine Building	O.P.+ 2,354 mm (18 mm increase since 7:00 on August 17)	O.P.+ 2,932 mm (10 mm decrease since 7:00 on August 17)	O.P.+ 3,085 mm (16 mm increase since 7:00 on August 17)	O.P.+ 3,023 mm (12 mm increase since 7:00 on August 17)
	Water level of Reactor Building	O.P.+ 4,382 mm (43 mm increase since 7:00 on August 17)	O.P.+ 3,097 mm (14 mm increase since 7:00 on August 17)	O.P.+ 3,173 mm (34 mm increase since 7:00 on August 17)	O.P.+ 3,003 mm (10 mm increase since 7:00 on August 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,008 mm (Increase from initial level:6,225 mm, 2 mm increase since 7:00 on August 17) O.P.+ 2,602 mm (Increase from initial level:3,328 mm, 85 mm decrease since 7:00 on August 17) O.P.+ 4,470 mm (Water level from floor:674 mm, 1 mm increase since 7:00 on August 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:28 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.