

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 19)**

Water Level of the accumulated water (at 7:00 on August 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,256 mm (19 mm increase since 7:00 on August 18)	O.P.+ 3,120 mm (50 mm increase since 7:00 on August 18)	—
	Water level of Turbine Building	O.P.+ 2,373 mm (19 mm increase since 7:00 on August 18)	O.P.+ 2,923 mm (9 mm decrease since 7:00 on August 18)	O.P.+ 3,105 mm (20 mm increase since 7:00 on August 18)	O.P.+ 3,038 mm (15 mm increase since 7:00 on August 18)
	Water level of Reactor Building	O.P.+ 4,379 mm (3 mm decrease since 7:00 on August 18)	O.P.+ 3,065 mm (32 mm decrease since 7:00 on August 18)	O.P.+ 3,200 mm (27 mm increase since 7:00 on August 18)	O.P.+ 3,014 mm (11 mm increase since 7:00 on August 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,012 mm (Increase from initial level:6,229 mm, 4 mm increase since 7:00 on August 18) O.P.+ 2,527 mm (Increase from initial level:3,253 mm, 75 mm decrease since 7:00 on August 18) O.P.+ 4,471 mm (Water level from floor:675 mm, 1 mm increase since 7:00 on August 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 14:28 on August 12 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.