

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 20)**

| | | | | | |
|--|--|---|--|--|--|
| Water Level of the accumulated water (at 7:00 on August 20) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 1,266 mm (10 mm increase since 7:00 on August 19) | O.P.+ 3,140 mm (20 mm increase since 7:00 on August 19) | — |
| | Water level of Turbine Building | O.P.+ 2,441 mm (68 mm increase since 7:00 on August 19) | O.P.+ 2,909 mm (14 mm decrease since 7:00 on August 19) | O.P.+ 3,126 mm (21 mm increase since 7:00 on August 19) | O.P.+ 3,051 mm (13 mm increase since 7:00 on August 19) |
| | Water level of Reactor Building | O.P.+ 4,362 mm (17 mm decrease since 7:00 on August 19) | O.P.+ 3,053 mm (12 mm decrease since 7:00 on August 19) | O.P.+ 3,226 mm (26 mm increase since 7:00 on August 19) | O.P.+ 3,025 mm (11 mm increase since 7:00 on August 19) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 5,016 mm (Increase from initial level:6,233 mm, 4 mm increase since 7:00 on August 19) O.P.+ 2,462 mm (Increase from initial level:3,188 mm, 65 mm decrease since 7:00 on August 19) O.P.+ 4,473 mm (Water level from floor:677 mm, 2 mm increase since 7:00 on August 19) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11) | — | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:16 on August 20 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.