

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 21)**

Water Level of the accumulated water (at 7:00 on August 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,565 mm (299 mm increase since 7:00 on August 20)	O.P.+ 3,170 mm (30 mm increase since 7:00 on August 20)	—
	Water level of Turbine Building	O.P.+ 2,461 mm (20 mm increase since 7:00 on August 20)	O.P.+ 2,894 mm (15 mm decrease since 7:00 on August 20)	O.P.+ 3,149 mm (23 mm increase since 7:00 on August 20)	O.P.+ 3,064 mm (13 mm increase since 7:00 on August 20)
	Water level of Reactor Building	O.P.+ 4,318 mm (44 mm decrease since 7:00 on August 20)	O.P.+ 3,042 mm (11 mm decrease since 7:00 on August 20)	O.P.+ 3,252 mm (26 mm increase since 7:00 on August 20)	O.P.+ 3,034 mm (9 mm increase since 7:00 on August 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,023 mm (Increase from initial level:6,240 mm, 7 mm increase since 7:00 on August 20) O.P.+ 2,488 mm (Increase from initial level:3,214 mm, 26 mm increase since 7:00 on August 20) O.P.+ 4,474 mm (Water level from floor:678 mm, 1 mm increase since 7:00 on August 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:22 on August 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.