

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 22)**

Water Level of the accumulated water (at 7:00 on August 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,594 mm (29 mm increase since 7:00 on August 21)	O.P.+ 3,120 mm (50 mm decrease since 7:00 on August 21)	—
	Water level of Turbine Building	O.P.+ 2,480 mm (19 mm increase since 7:00 on August 21)	O.P.+ 2,881 mm (13 mm decrease since 7:00 on August 21)	O.P.+ 3,103 mm (46 mm decrease since 7:00 on August 21)	O.P.+ 3,074 mm (10 mm increase since 7:00 on August 21)
	Water level of Reactor Building	O.P.+ 4,309 mm (9 mm decrease since 7:00 on August 21)	O.P.+ 3,033 mm (9 mm decrease since 7:00 on August 21)	O.P.+ 3,208 mm (44 mm decrease since 7:00 on August 21)	O.P.+ 3,043 mm (9 mm increase since 7:00 on August 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,027 mm (Increase from initial level:6,244 mm, 4 mm increase since 7:00 on August 21) O.P.+ 2,820 mm (Increase from initial level:3,546 mm, 332 mm increase since 7:00 on August 21) O.P.+ 4,474 mm (Water level from floor:678 mm, No change since 7:00 on August 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:29 on August 21)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:22 on August 20 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.