

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 24)**

Water Level of the accumulated water (at 7:00 on August 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,613 mm (11 mm increase since 7:00 on August 23)	O.P.+ 3,160 mm (30 mm increase since 7:00 on August 23)	—
	Water level of Turbine Building	O.P.+ 2,383 mm (114 mm decrease since 7:00 on August 23)	O.P.+ 2,853 mm (12 mm decrease since 7:00 on August 23)	O.P.+ 3,154 mm (25 mm increase since 7:00 on August 23)	O.P.+ 3,090 mm (12 mm increase since 7:00 on August 23)
	Water level of Reactor Building	O.P.+ 4,333 mm (20 mm increase since 7:00 on August 23)	O.P.+ 3,009 mm (11 mm decrease since 7:00 on August 23)	O.P.+ 3,267 mm (37 mm increase since 7:00 on August 23)	O.P.+ 3,058 mm (7 mm increase since 7:00 on August 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,066 mm (Increase from initial level:6,283 mm, 37 mm increase since 7:00 on August 23) O.P.+ 2,696 mm (Increase from initial level:3,422 mm, 91 mm decrease since 7:00 on August 23) O.P.+ 4,355 mm (Water level from floor:559 mm, 121 mm decrease since 7:00 on August 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 10:10 on August 23 to 13:58 on August 23)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 12:22 on August 20   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.