

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 25)**

Water Level of the accumulated water (at 7:00 on August 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,620 mm (7 mm increase since 7:00 on August 24)	O.P.+ 3,190 mm (30 mm increase since 7:00 on August 24)	—
	Water level of Turbine Building	O.P.+ 2,402 mm (19 mm increase since 7:00 on August 24)	O.P.+ 2,840 mm (13 mm decrease since 7:00 on August 24)	O.P.+ 3,173 mm (19 mm increase since 7:00 on August 24)	O.P.+ 3,103 mm (13 mm increase since 7:00 on August 24)
	Water level of Reactor Building	O.P.+ 4,326 mm (7 mm decrease since 7:00 on August 24)	O.P.+ 2,986 mm (23 mm decrease since 7:00 on August 24)	O.P.+ 3,295 mm (28 mm increase since 7:00 on August 24)	O.P.+ 3,067 mm (9 mm increase since 7:00 on August 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,067 mm (Increase from initial level:6,284 mm, 1 mm increase since 7:00 on August 24) O.P.+ 2,605 mm (Increase from initial level:3,331 mm, 91 mm decrease since 7:00 on August 24) O.P.+ 4,356 mm (Water level from floor:560 mm, 1 mm increase since 7:00 on August 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 18:32 on August 11)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 7:20 on August 25 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.