

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 27)**

| | | | | | |
|--|--|---|---|--|--|
| Water Level of the accumulated water (at 7:00 on August 27) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 890 mm (105 mm increase since 7:00 on August 26) | O.P.+ 3,230 mm (30 mm increase since 7:00 on August 26) | — |
| | Water level of Turbine Building | O.P.+ 2,442 mm (21 mm increase since 7:00 on August 26) | O.P.+ 2,901 mm (72 mm increase since 7:00 on August 26) | O.P.+ 3,222 mm (30 mm increase since 7:00 on August 26) | O.P.+ 3,131 mm (14 mm increase since 7:00 on August 26) |
| | Water level of Reactor Building | O.P.+ 4,377 mm (61 mm increase since 7:00 on August 26) | O.P.+ 3,025 mm (48 mm increase since 7:00 on August 26) | O.P.+ 3,350 mm (39 mm increase since 7:00 on August 26) | O.P.+ 3,089 mm (11 mm increase since 7:00 on August 26) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 5,071 mm (Increase from initial level:6,288 mm, 3 mm increase since 7:00 on August 26) O.P.+ 2,128 mm (Increase from initial level:2,854 mm, 508 mm decrease since 7:00 on August 26) O.P.+ 4,358 mm (Water level from floor:562 mm, 2 mm increase since 7:00 on August 26) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer suspended (Since 9:44 on August 26) | — | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:29 on August 27 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.