

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 28)**

Water Level of the accumulated water (at 7:00 on August 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,127 mm (237 mm increase since 7:00 on August 27)	O.P.+ 3,230 mm (No change since 7:00 on August 27)	—
	Water level of Turbine Building	O.P.+ 2,467 mm (25 mm increase since 7:00 on August 27)	O.P.+ 2,943 mm (42 mm increase since 7:00 on August 27)	O.P.+ 3,218 mm (4 mm decrease since 7:00 on August 27)	O.P.+ 3,148 mm (17 mm increase since 7:00 on August 27)
	Water level of Reactor Building	O.P.+ 4,514 mm (137 mm increase since 7:00 on August 27)	O.P.+ 3,099 mm (74 mm increase since 7:00 on August 27)	O.P.+ 3,355 mm (5 mm increase since 7:00 on August 27)	O.P.+ 3,102 mm (13 mm increase since 7:00 on August 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,075 mm (Increase from initial level:6,292 mm, 4 mm increase since 7:00 on August 27) O.P.+ 2,334 mm (Increase from initial level:3,060 mm, 206 mm increase since 7:00 on August 27) O.P.+ 4,364 mm (Water level from floor:568 mm, 6 mm increase since 7:00 on August 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:39 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:52 on August 27)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:20 on August 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.