

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 29)**

Water Level of the accumulated water (at 7:00 on August 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,245 mm (118 mm increase since 7:00 on August 28)	O.P.+ 3,200 mm (30 mm decrease since 7:00 on August 28)	—
	Water level of Turbine Building	O.P.+ 2,499 mm (32 mm increase since 7:00 on August 28)	O.P.+ 2,949 mm (6 mm increase since 7:00 on August 28)	O.P.+ 3,176 mm (42 mm decrease since 7:00 on August 28)	O.P.+ 3,156 mm (8 mm increase since 7:00 on August 28)
	Water level of Reactor Building	O.P.+ 4,583 mm (69 mm increase since 7:00 on August 28)	O.P.+ 3,098 mm (1 mm decrease since 7:00 on August 28)	O.P.+ 3,302 mm (53 mm decrease since 7:00 on August 28)	O.P.+ 3,111 mm (9 mm increase since 7:00 on August 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,079 mm (Increase from initial level:6,296 mm, 4 mm increase since 7:00 on August 28) O.P.+ 2,716 mm (Increase from initial level:3,442 mm, 382 mm increase since 7:00 on August 28) O.P.+ 4,368 mm (Water level from floor:572 mm, 4 mm increase since 7:00 on August 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:39 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:52 on August 27)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:20 on August 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.