

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 30)**

Water Level of the accumulated water (at 7:00 on August 30)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,419 mm (174 mm increase since 7:00 on August 29)	O.P.+ 3,180 mm (20 mm decrease since 7:00 on August 29)	—
	Water level of Turbine Building	O.P.+ 2,515 mm (16 mm increase since 7:00 on August 29)	O.P.+ 2,960 mm (11 mm increase since 7:00 on August 29)	O.P.+ 3,154 mm (22 mm decrease since 7:00 on August 29)	O.P.+ 3,153 mm (3 mm decrease since 7:00 on August 29)
	Water level of Reactor Building	O.P.+ 4,718 mm (135 mm increase since 7:00 on August 29)	O.P.+ 3,120 mm (22 mm increase since 7:00 on August 29)	O.P.+ 3,272 mm (30 mm decrease since 7:00 on August 29)	O.P.+ 3,118 mm (7 mm increase since 7:00 on August 29)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,082 mm (Increase from initial level:6,299 mm, 3 mm increase since 7:00 on August 29) O.P.+ 3,164 mm (Increase from initial level:3,890 mm, 448 mm increase since 7:00 on August 29) O.P.+ 4,373 mm (Water level from floor:577 mm, 5 mm increase since 7:00 on August 29)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (Since 6:02 on August 30)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:39 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:52 on August 27)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:20 on August 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.