

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on August 31)**

Water Level of the accumulated water (at 7:00 on August 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,505 mm (86 mm increase since 7:00 on August 30)	O.P.+ 3,160 mm (20 mm decrease since 7:00 on August 30)	—
	Water level of Turbine Building	O.P.+ 2,396 mm (119 mm decrease since 7:00 on August 30)	O.P.+ 2,973 mm (13 mm increase since 7:00 on August 30)	O.P.+ 3,165 mm (11 mm increase since 7:00 on August 30)	O.P.+ 3,146 mm (7 mm decrease since 7:00 on August 30)
	Water level of Reactor Building	O.P.+ 4,825 mm (107 mm increase since 7:00 on August 30)	O.P.+ 3,133 mm (13 mm increase since 7:00 on August 30)	O.P.+ 3,278 mm (6 mm increase since 7:00 on August 30)	O.P.+ 3,120 mm (2 mm increase since 7:00 on August 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,086 mm (Increase from initial level:6,303 mm, 4 mm increase since 7:00 on August 30) O.P.+ 3,443 mm (Increase from initial level:4,169 mm, 279 mm increase since 7:00 on August 30) O.P.+ 4,376 mm (Water level from floor:580 mm, 3 mm increase since 7:00 on August 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 6:02 on August 30 to 11:20 on August 30)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 16:39 on August 27)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 16:52 on August 27 to 22:08 on August 30)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:20 on August 27   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.