

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 1)**

Water Level of the accumulated water (at 7:00 on September 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,588 mm (83 mm increase since 7:00 on August 31)	O.P.+ 3,200 mm (40 mm increase since 7:00 on August 31)	—
	Water level of Turbine Building	O.P.+ 2,455 mm (59 mm increase since 7:00 on August 31)	O.P.+ 2,999 mm (26 mm increase since 7:00 on August 31)	O.P.+ 3,208 mm (43 mm increase since 7:00 on August 31)	O.P.+ 3,154 mm (8 mm increase since 7:00 on August 31)
	Water level of Reactor Building	O.P.+ 4,891 mm (66 mm increase since 7:00 on August 31)	O.P.+ 3,143 mm (10 mm increase since 7:00 on August 31)	O.P.+ 3,326 mm (48 mm increase since 7:00 on August 31)	O.P.+ 3,124 mm (4 mm increase since 7:00 on August 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 5,089 mm (Increase from initial level:6,306 mm, 3 mm increase since 7:00 on August 31) O.P.+ 3,229 mm (Increase from initial level:3,955 mm, 214 mm decrease since 7:00 on August 31) O.P.+ 4,381 mm (Water level from floor:585 mm, 5 mm increase since 7:00 on August 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 16:39 on August 27 to 5:04 on September 1)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on August 31 to 15:00 on August 31)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:51 on July 14 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:20 on August 27 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.