

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on September 3)**

Water Level of the accumulated water (at 7:00 on September 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,698 mm (51 mm increase since 7:00 on September 2)	O.P.+ 3,280 mm (50 mm increase since 7:00 on September 2)	—
	Water level of Turbine Building	O.P.+ 2,542 mm (43 mm increase since 7:00 on September 2)	O.P.+ 3,106 mm (4 mm increase since 7:00 on September 2)	O.P.+ 3,265 mm (29 mm increase since 7:00 on September 2)	O.P.+ 3,180 mm (13 mm increase since 7:00 on September 2)
	Water level of Reactor Building	O.P.+ 4,932 mm (14 mm increase since 7:00 on September 2)	O.P.+ 3,248 mm (43 mm increase since 7:00 on September 2)	O.P.+ 3,395 mm (35 mm increase since 7:00 on September 2)	O.P.+ 3,138 mm (8 mm increase since 7:00 on September 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,990 mm (Increase from initial level:6,207 mm, 110 mm decrease since 7:00 on September 2) O.P.+ 2,481 mm (Increase from initial level:3,207 mm, 122 mm decrease since 7:00 on September 2) O.P.+ 4,384 mm (Water level from floor:588 mm, 2 mm increase since 7:00 on September 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 14:18 on September 2 to 7:50 on September 3)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on September 2 to 15:00 on September 2)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:09 on September 2 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 8:29 on September 3 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.